## STATE OF COLORADO

Bill Owens, Governor Jane E. Norton, Executive Director

Dedicated to protecting and improving the health and environment of the people of Colorado

4300 Cherry Creek Dr. S. Denver, Colorado 80246-1530 Phone (303) 692-2000 TDD Line (303) 691-7700 Located in Glendale, Colorado

http://www.cdphe.state.co.us

Laboratory and Radiation Services Division 8100 Lowry Blvd. Denver, Colorado 80230-6928 (303) 692-3090



March 22, 2002

Mr. Joseph A Legare Assistant Manager for Environment and Infrastructure U.S. Department of Energy, Rocky Flats Field Office 10808 Highway 93, Unit A Golden, CO 80403-8200

RE: B662 and B551 Change from Type 2 to Type 1

Dear Mr. Legare:

The Colorado Department of Public Health and Environment, Hazardous Materials and Waste Management Division (the Division) has reviewed your letter dated March 11, 2002 requesting Buildings 662 and 551 be changed from their current status as Type 2 Facilities to Type 1 Facilities. Upon reviewing the information provided, the Division hereby concurs with this change with the following comments:

- 1) The information provided indicates that the elevated radiological readings on the exterior building surfaces are not due to the presence of DOE added contamination as previously indicated. As such, B551 can be re-designated as a Type 1 Facility. However, as indicated in your letter, only the above slab portion of B662 is to be re-designated as a Type 1 Facility, with the B662 slab continuing to be identified as a potentially contaminated Type 2 structure.
- 2) Since both facilities have been utilized after the initial RLC was performed, and as indicated in your letter, PDSs will be performed prior to starting demolition to show that these facilities have not been contaminated.

If you have any questions regarding this correspondence please contact me at (303) 692-3367 or David Kruchek at (303) 692-3328.

Sincere

RFCA Project Coordinator

cc: Steve Tower, FCG, RFFO

Tim Rehder, EPA Duane Parsons, KH Frank Gibbs, KH

Administrative Records Building T130G

RECEIVED RECORDS CENTER

ADMIN RECORD

IA-A-000927